

WASTE WATER PLANTS IN THE TANA RIVER SYSTEM- INFORMATION SHEET

Name of waste water plant: Rustefjeldbma waste water treatment plant

Owner: Tana municipality

Operator: Tana

Located in (municipality): Tana and (country): Norway

Basic information on treatment, discharge and permit

Year of construction: 1993

Type of treatment: Chemical treatment (sedimentation)

Location of outlet (coordinates and UTM code): X= 810709.30 Y= 544774,88 (EUREF 89, zone 35)

Max. allowed discharge in permit (PE): 300 PE

Discharge per 2017 in PE: 171 PE

Number of households connected: 37 households.

Type of industry connected: None

Annual discharge of phosphorous (P)(kg/year): 2

Annual discharge of nitrogen (N)(kg/year):

Annual discharge of organic matter (BOF/BOD7) (kg/year): 115 BOF5

Suspended solids (SS/STS) (kg/year): 304